

Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyse*


Test Report				Report No. AB/ACI/08/2022-23/512	
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220		Sample Code	AB/ACI/08/2022-23/512		
		Sample Name	ETP Outlet		
		Sample Collected By	Aavanira Biotech Pvt Ltd		
		Method for Sampling	IS 3025 (Part 1)		
		Sample Type	Effluent		
		Sample Collected On	20/08/2022		
		Sample Received on Date	20/08/2022		
		Analysis Date	22/08/2022 to 26/08/2022		
		Reporting Date	27/08/2022		
Sample returned /stored		Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Limit as per MPCB Consent	Unit	Standard Method
1.	Total Suspended Solids	2.0	100	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Total Dissolved Solids	116.0	2100	mg/lit	IS: 3025 Part-16 (R.A : 2017)
3.	pH	6.51	5.5-9.0	--	IS: 3025 Part-11 (R.A : 2017)
4.	Biochemical Oxygen Demand (3 day test at 27°C)	11.0	100	mg/lit	IS: 3025 Part-44 (R.A : 2019)
5.	Chemical Oxygen Demand	44.53	250	mg/lit	IS: 3025 Part-58 (R.A : 2017)
6.	Chlorides (as Cl ⁻)	21.35	600	mg/lit	IS: 3025 Part-32 (R.A : 2019)
7.	Sulphate (as SO ₄ ⁻²)	13.5	1000	mg/lit	APHA :23 rd edition -(4500- SO ₄ ²⁻ E)
8.	Phenol	BDL	5	mg/lit	IS: 3025 Part-43 (R.A : 2019)
9.	Sulphide (as S ⁻²)	BDL	2	mg/lit	APHA :23 rd edition -(4500- SO ²⁻ F)
10.	Oil and grease	BDL	10	mg/lit	IS: 3025 Part-39 (R.A : 2021)

BDL: Below Detection Limit.

Remark & Observations: All above parameters are within Limit as per MPCB Consent.


Verified By – Quality Manager


Authorized By – Technical Manager /
Dy. Technical Manager


Govt. Analyst
-----End of Report-----




Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report		Report No. AB/ACI/08/2022-23/513		
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220	Sample Code	AB/ACI/08/2022-23/513		
	Sample Name	STP Outlet		
	Sample Collected By	Aavanira Biotech Pvt Ltd		
	Method for Sampling	IS 3025 (Part 1)		
	Sample Type	Sewage		
	Sample Collected On	20/08/2022		
	Sample Received on Date	20/08/2022		
	Analysis Date	22/08/2022 to 26/08/2022		
	Reporting Date	27/08/2022		
Sample returned /stored	Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Unit	Standard Method
1.	Total Suspended Solids	29.0	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Biochemical Oxygen Demand (3 day test at 27°C)	30.0	mg/lit	IS: 3025 Part-44 (R.A : 2019)


Verified By – Quality Manager


Authorized By – Technical Manager /
Dy. Technical Manager


Govt. Analyst
—End of Report—



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyse*

Test Report			Report No. AB/ACI/09/2022-23/212		
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220		Sample Code	AB/ACI/09/2022-23/212		
		Sample Name	ETP Outlet		
		Sample Collected By	Client		
		Method for Sampling	-		
		Sample Type	Effluent		
		Sample Collected On	10/09/2022		
		Sample Received on Date	10/09/2022		
		Analysis Date	12/09/2022 to 16/09/2022		
		Reporting Date	17/09/2022		
Sample returned /stored		Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Limit as per MPCB Consent	Unit	Standard Method
1.	Total Suspended Solids	1.0	100	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Total Dissolved Solids	262.0	2100	mg/lit	IS: 3025 Part-16 (R.A : 2017)
3.	pH	7.44	5.5-9.0	-	IS: 3025 Part-11 (R.A : 2017)
4.	Biochemical Oxygen Demand (3 day test at 27°C)	8.0	100	mg/lit	IS: 3025 Part-44 (R.A : 2019)
5.	Chemical Oxygen Demand	32.26	250	mg/lit	IS: 3025 Part-58 (R.A : 2017)
6.	Chlorides (as Cl ⁻)	47.56	600	mg/lit	IS: 3025 Part-32 (R.A : 2019)
7.	Sulphate (as SO ₄ ⁻²)	4.0	1000	mg/lit	APHA :23 rd edition -(4500- SO ₄ ²⁻ E)
8.	Phenol	BDL	5	mg/lit	IS: 3025 Part-43 (R.A : 2019)
9.	Sulphide (as S ⁻²)	BDL	2	mg/lit	APHA :23 rd edition -(4500- SO ₂ ⁻² F)
10.	Oil and grease	BDL	10	mg/lit	IS: 3025 Part-39 (R.A : 2021)

BDL: Below Detection Limit.

Remark & Observations: All above parameters are within Limit as per MPCB Consent.


Verified By – Quality Manager


Govt. Analyst
-----End of Report-----



Authorized By – Technical Manager /
Dy. Technical Manager



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report			Report No. AB/ACI/09/2022-23/211	
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220	Sample Code	AB/ACI/09/2022-23/211		
	Sample Name	STP Outlet		
	Sample Collected By	Client		
	Method for Sampling	-		
	Sample Type	Sewage		
	Sample Collected On	10/09/2022		
	Sample Received on Date	10/09/2022		
	Analysis Date	12/09/2022 to 16/09/2022		
	Reporting Date	17/09/2022		
Sample returned /stored	Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Unit	Standard Method
1.	Total Suspended Solids	128.0	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Biochemical Oxygen Demand (3 day test at 27°C)	17.0	mg/lit	IS: 3025 Part-44 (R.A : 2019)


Verified By – Quality Manager


Govt. Analyst
—End of Report—


Authorized By – Technical Manager /
Dy. Technical Manager



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report			Report No. AB/ACI/10/2022-23/539		
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220		Sample Code	AB/ACI/10/2022-23/539		
		Sample Name	ETP Outlet		
		Sample Collected By	Client		
		Method for Sampling	-		
		Sample Type	Effluent		
		Sample Collected On	17/10/2022		
		Sample Received on Date	17/10/2022		
		Analysis Date	18/10/2022 to 22/10/2022		
		Reporting Date	22/10/2022		
Sample returned /stored		Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Limit as per MPCB Consent	Unit	Standard Method
1.	Total Suspended Solids	1.0	100	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Total Dissolved Solids	269.0	2100	mg/lit	IS: 3025 Part-16 (R.A : 2017)
3.	pH	7.51	5.5-9.0	--	IS: 3025 Part-11 (R.A : 2017)
4.	Biochemical Oxygen Demand (3 day test at 27°C)	10.0	100	mg/lit	IS: 3025 Part-44 (R.A : 2019)
5.	Chemical Oxygen Demand	32.11	250	mg/lit	IS: 3025 Part-58 (R.A : 2017)
6.	Chlorides (as Cl ⁻)	51.02	600	mg/lit	IS: 3025 Part-32 (R.A : 2019)
7.	Sulphate (as SO ₄ ⁻²)	5.28	1000	mg/lit	APHA :23 rd edition -(4500- SO ₄ ²⁻ E)
8.	Phenol	BDL	5	mg/lit	IS: 3025 Part-43 (R.A : 2019)
9.	Sulphide (as S ⁻²)	BDL	2	mg/lit	APHA :23 rd edition -(4500- SO ₂ ⁻² F)
10.	Oil and grease	BDL	10	mg/lit	IS: 3025 Part-39 (R.A : 2021)

BDL: Below Detection Limit.

Remark & Observations: All above parameters are within Limit as per MPCB Consent.



Verified By – Quality Manager



Authorized By – Technical Manager /
Dy. Technical Manager



Govt. Analyst


-----End of Report-----



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report			Report No. AB/ACI/10/2022-23/538	
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220	Sample Code	AB/ACI/10/2022-23/538		
	Sample Name	STP Outlet		
	Sample Collected By	Client		
	Method for Sampling	-		
	Sample Type	Sewage		
	Sample Collected On	17/10/2022		
	Sample Received on Date	17/10/2022		
	Analysis Date	18/10/2022 to 22/10/2022		
	Reporting Date	22/10/2022		
Sample returned /stored	Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Unit	Standard Method
1.	Total Suspended Solids	134.0	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Biochemical Oxygen Demand (3 day test at 27°C)	19.0	mg/lit	IS: 3025 Part-44 (R.A : 2019)


Verified By – Quality Manager


Govt. Analyst
—End of Report—


Authorized By – Technical Manager /
Dy. Technical Manager



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report				Report No. AB/ACI/11/2022-23/519	
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220		Sample Code	AB/ACI/11/2022-23/519		
		Sample Name	ETP Outlet		
		Sample Collected By	Client		
		Method for Sampling	-		
		Sample Type	Effluent		
		Sample Collected On	12/11/2022		
		Sample Received on Date	12/11/2022		
		Analysis Date	14/11/2022 to 18/11/2022		
		Reporting Date	19/11/2022		
Sample returned /stored		Stored at 4°C for 1 week from the date of reporting			
Sr. No.	Parameter	Result	Limit as per MPCB Consent	Unit	Standard Method
1.	Total Suspended Solids	2.0	100	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Total Dissolved Solids	85.0	2100	mg/lit	IS: 3025 Part-16 (R.A : 2017)
3.	pH	7.65	5.5-9.0	--	IS: 3025 Part-11 (R.A : 2017)
4.	Biochemical Oxygen Demand (3 day test at 27°C)	4.0	100	mg/lit	IS: 3025 Part-44 (R.A : 2019)
5.	Chemical Oxygen Demand	12.24	250	mg/lit	IS: 3025 Part-58 (R.A : 2017)
6.	Chlorides (as Cl ⁻)	31.42	600	mg/lit	IS: 3025 Part-32 (R.A : 2019)
7.	Sulphate (as SO ₄ ⁻²)	4.3	1000	mg/lit	APHA :23 rd edition -(4500- SO ₄ ²⁻ E)
8.	Phenol	BDL	5	mg/lit	IS: 3025 Part-43 (R.A : 2019)
9.	Sulphide (as S ⁻²)	BDL	2	mg/lit	APHA :23 rd edition -(4500- SO ²⁻ F)
10.	Oil and grease	BDL	10	mg/lit	IS: 3025 Part-39 (R.A : 2021)

BDL: Below Detection Limit.

Remark & Observations: All above parameters are within Limit as per MPCB Consent.

Verified By – Quality Manager

Authorized By – Technical Manager /
Dy. Technical Manager

Govt. Analyst
----End of Report----



Recognized by Ministry of Environment, Forest & Climate Change (MoEFCC), Govt. of India
ISO 9001: 2015 and ISO 45001: 2018 Certified Company

ENalyze*

Test Report		Report No. AB/ACI/11/2022-23/520		
Client Details Name & Address: M/s. ASK Chemicals India Pvt. Ltd. E-89, MIDC Ranjangaon, Nagar Road, Tal. Shirur, Pune 412 220	Sample Code	AB/ACI/11/2022-23/520		
	Sample Name	STP Outlet		
	Sample Collected By	Client		
	Method for Sampling	-		
	Sample Type	Sewage		
	Sample Collected On	12/11/2022		
	Sample Received on Date	12/11/2022		
	Analysis Date	14/11/2022 to 18/11/2022		
	Reporting Date	19/11/2022		
Sample returned /stored		Stored at 4°C for 1 week from the date of reporting		
Sr. No.	Parameter	Result	Unit	Standard Method
1.	Total Suspended Solids	312.0	mg/lit	IS: 3025 Part-17 (R.A : 2017)
2.	Biochemical Oxygen Demand (3 day test at 27°C)	22.0	mg/lit	IS: 3025 Part-44 (R.A : 2019)


Verified By – Quality Manager


Authorized By – Technical Manager /
Dy. Technical Manager


Govt. Analyst
-----End of Report-----

